



Product Service

Attestation of Conformity

No. N8A 16 05 92420 002

Holder of Certificate: ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO., LTD.

Wei 11th Road, Economic Development Zone,
325600 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: Tubular fuses
Fuse-links for the protection of semiconductor devices

Model(s): RGS7; RGS7Z

Parameters:

Fuse Type:	Type A Fig.CC.1
Rated Voltage:	AC 690V/700V
Rated Frequency:	50Hz
Rated Current:	
RGS7:	40A, 45A, 50A, 55A, 63A, 70A, 75A, 80A, 90A, 100A, 110A, 125A, 140A, 150A, 160A, 180A, 200A, 225A, 250A, 260A, 280A, 300A, 315A
RGS7Z:	40A, 45A, 50A, 55A, 63A, 70A, 75A, 80A, 90A, 100A, 110A, 125A, 140A, 150A, 160A, 180A, 200A, 225A, 250A, 260A, 280A, 300A, 315A
Breaking Range And Utilization Category:	
	aR
Rated Breaking Capacity:	50kA

Tested according to: EN 60269-4:2009/A1:2012
EN 60269-1:2007/A2:2014

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 705201508401-00

Boris Ouyang

Date, 2016-06-16 (Boris Ouyang)



CE After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.