

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN45528

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fuse-switch-disconnectors

Name and address of the applicant

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Yueqing Economic Development Zone,
Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Yueqing Economic Development Zone,
Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road, Economic Development Zone, Yueqing,
Zhejiang 325600 P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:8kV;Ui: 1000V;lth: 400A;AC-23B: Ue/ Ie:
AC690V/400A;lq: 50kA;3P; 50/60Hz.

Trademark (if any)

MiRO

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

MRO.H1(DR1)-400

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 (5th Edition) + AMD1:2010 +
AMD2:2014;IEC 60947-3:2008(3rd Edition) + AMD 1:2012 +
AMD 2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-082190

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.26,2018

Signature:

Lu Mei

CB 0049696