



# 产品认证证书

证书编号：CQC2019010302174157

## 申请人名称及地址

美尔森电气系统（浙江）有限公司  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

## 制造商名称及地址

美尔森电气系统（浙江）有限公司  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

## 生产企业名称及地址

美尔森电气系统（浙江）有限公司 (V055926)  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

## 产品名称和系列、规格、型号

### 熔断器式隔离开关

MRO.H2(DR2)-160; 额定冲击耐受电压(Uimp): 8kV; 额定绝缘电压(Ui): 1000V; 约定发热电流(Ith): 160A; 额定工作电压(Ue): AC500V, AC690V; 额定工作电流(Ie): 160A; 额定限制短路电流(Iq): 100kA/AC500V, 50kA/AC690V; 使用类别: AC-23B; 极数: 3P; 适用频率: 50/60Hz

## 产品标准和技术要求

GB/T 14048.3-2017

## 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求，特发此证。

发证日期：2020 年 10 月 31 日 有效期至：2023 年 03 月 28 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2020 年 04 月 24 日

主任： 陆杨



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0425481



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010302174157

## NAME AND ADDRESS OF THE APPLICANT

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE FACTORY

MERSEN ZHEJIANG CO., LTD. (V055926)

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Fuse switch-disconnector

MRO.H2(DR2)-160;Uimp: 8kV; Ui:1000V; Ith:160A; Ue: AC500V,AC690V;  
Ie:160A;Iq:100kA/500V,50kA/690V; Utilization Category:AC- 23B; Poles:3P;50/60Hz

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Oct.31,2020


Valid until: Mar.28,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.24,2020

President: \_\_\_\_\_

Lu Mei



# CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0425481