



# 产品认证证书

证书编号：CQC2010010308421254

申请人名称及地址

美尔森电气系统（浙江）有限公司  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

制造商名称及地址

美尔森电气系统（浙江）有限公司  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

生产企业名称及地址

美尔森电气系统（浙江）有限公司(V055926)  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

产品名称和系列、规格、型号

低压熔断器（刀型触头熔断器）

熔断体型号:NH2;熔断体的额定电压:500V/690V;熔断体的额定电  
流:125A,160A,200A,224A,250A,300A,315A,355A,400A(500V);125A,160A,200A,224A,250A(690V);额定分断能  
力:100kA(500V),50kA(690V);分断范围和使用类别:gG;熔断体支持件型号:NH2;熔断体支持件的额定电压:690V;  
熔断体支持件的额定电流:400A;极数:1P;峰值耐受电流:100kA

产品标准和技术要求

GB/T 13539.2-2015

认证模式

产品型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求，特发此证。

发证日期：2020 年 10 月 31 日 有效期至：2024 年 09 月 25 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2020 年 04 月 24 日

主任：陆楠



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0425462



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010308421254

## NAME AND ADDRESS OF THE APPLICANT

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE FACTORY

MERSEN ZHEJIANG CO., LTD. (V055926)

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

fuse with breaking capacity of all ranges

Fuse

Model:NH2;Un:500V/690V;In:125A,160A,200A,224A,250A,300A,315A,355A,400A(500V);125A,160A,200A,224A,250A(690V);I1:100kA(500V),50kA(690V);Breaking Range and Utilization Category:gG; Fuse-holder  
Model:NH2;Un:690V;In:400A;Poles:1P;Peak Withstand Current:100kA

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Oct.31,2020

Valid until: Sep.25,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.24,2020

President: \_\_\_\_\_

Lu Mei



# CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0425462