



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010308421255

NAME AND ADDRESS OF THE APPLICANT

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

MERSEN ZHEJIANG CO., LTD. (V055926)

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse with breaking capacity of all ranges

NH3; Fuse-link : Un: AC500V; In: 315A, 355A, 400A, 425A, 500A, 630A; Un: AC690V; In: 315A, 355A, 400A, 425A, 500A; I1: 100kA (AC500V) , 50kA (AC690V) ; gG; Fuse-holder: Un: AC690V; In: 630A; Poles: 1P; Peak withstand current : 100kA;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Oct.31,2020

Valid until: Sep.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.24,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0425463